

# 2019 Consumer Confidence Report Data PITTSVILLE WATERWORKS, PWS ID: 77201124

## Water System Information

If you would like to know more about the information contained in this report, please contact Peter Petersen at (715) 884-2295.

## Opportunity for input on decisions affecting your water quality

Second Wednesday of every month at 5:00PM is the Water and Sewer Commission Meeting, and the third Tuesday of every Month at 6:00PM is the City Council Meetings. Both held at the Municipal Building located at 5318 1st Ave Pittsville, WI 54466.

## Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

## Source(s) of Water

Source ID	Source	Depth (in feet)	Status
4	Groundwater	353	Active
5	Groundwater	400	Active
6	Groundwater	300	Active

Source ID	Source	Depth (in feet)	Status
7	Groundwater		Temp. out of Service as of
8	Groundwater		Active
9	Groundwater		Active

To obtain a summary of the source water assessment please contact, Peter Petersen at (715) 884-2295.

## Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

## Definitions

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.

<b>Term</b>	<b>Definition</b>
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

## **Detected Contaminants**

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

## **Disinfection Byproducts**

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2019)	Violation	Typical Source of Contaminant
HAA5 (ppb)	D-1-DBP	60	60	11	11	7/10/2018	No	By-product of drinking water chlorination
TTHM (ppb)	D-1-DBP	80	0	50.7	50.7	7/10/2018	No	By-product of drinking water chlorination

### Inorganic Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2019)	Violation	Typical Source of Contaminant
BARIUM (ppm)		2	2	0.176	0.121 - 0.176	2/9/2017	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE (ppm)		4	4	0.1	0.1 - 0.1	2/9/2017	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE (N03-N) (ppm)		10	10	1.48	0.52 - 1.48		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRITE (N02-N) (ppm)		1	1	0.026	0.017 - 0.026	2/9/2017	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SELENIUM (ppb)		50	50	0	0 - 0	2/9/2017	No	Discharge from petroleum and metal refineries; Erosion of natural deposits;

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2019)	Violation	Typical Source of Contaminant
								Discharge from mines
SODIUM (ppm)		n/a	n/a	92.40	49.70 - 92.40	2/9/2017	No	n/a

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2019)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.5760	0 of 10 results were above the action level.	6/7/2017	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	1.04	0 of 10 results were above the action level.	6/6/2017	No	Corrosion of household plumbing systems; Erosion of natural deposits

### Radioactive Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2019)	Violation	Typical Source of Contaminant
GROSS ALPHA, EXCL. R & U (pCi/l)		15	0	1.2	1.2	2/9/2017	No	Erosion of natural deposits
RADIUM, (226 + 228) (pCi/l)		5	0	1.0	1.0	2/9/2017	No	Erosion of natural deposits
GROSS ALPHA, INCL. R & U (n/a)		n/a	n/a	1.3	1.3	2/9/2017	No	Erosion of natural deposits

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2019)	Violation	Typical Source of Contaminant
COMBINED URANIUM (ug/l)		30	0	0.1	0.1	2/9/2017	No	Erosion of natural deposits

### Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Pittsville Waterworks is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

### Other Compliance

#### Monitoring Violations

Description	Contaminant Group	Sample Location	Compliance Period Beginning	Compliance Period Ending
DBP Monitoring/Reporting	Dbp	Distribution System	7/1/2019	9/30/2019

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the compliance period noted in the above table, we did not complete all monitoring or testing for the contaminant(s) noted, and therefore cannot be sure of the quality of your drinking water during that time.

#### Actions Taken

I was using an outdated monitoring site plan, but now will be using the up-to-date monitoring site plan that comes with the monitoring schedule.

### Violation of the Terms of a Variance, Exemption, or Administrative or Judicial Order

Our sample for the distribution of Disinfection Byproducts was sampled at the incorrect sample site. I was going off of an old monitoring site plan.

### **Noncompliance with Recordkeeping and Compliance Data**

I will be doing the Disinfection Byproducts sample in July of 2020 and will be kept no less than 3 years as per NR 809.82(2).

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one in a million chance of having the described health effect.

In our continuing efforts to maintain a safe and dependable water supply, it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. Please call our office 715-884-2422 if you have any questions. At Pittsville Waterworks, we work hard to provide top quality water to every tap in our city. We ask that all our customers help us protect our water sources which are the heart of our community, our way of life, and our children's future.